



## Fire Lane No Parking Sign Locations




## Fire Lane Sign Post Installation

1. Height of the sign: 7' in sidewalk or pedestrian areas, 5' in all other areas.
2. Distance from front of curb: 18" with standard curb, 24" with rolled curb, to center of post.
3. Depth of sign base: 24" minimum embedment.

NOTE: Signs may be mounted to an existing post or on a building that is no more than 24" from curb or edge of road surface.

### Mounting Specifications for Fire Lane Entrance and No Parking Signs



Signs shall be mounted facing the direction of vehicular travel.

Signs may be mounted on existing posts or buildings where the centerline of the sign is no more than 24" from the edge of the roadway.

Depth of bury shall be a *minimum* of 24".

